


THE CITY OF  
**POMONA**

Water Operations



September 6, 2016

TO: All Bidders

**RE: ADDENDUM NO. 3 FOR 1577 W. 2<sup>nd</sup> STREET – RESERVOIR SITE SECURITY UPGRADE, “WATER FACILITIES AND SECURITY UPGRADES”, PROJECT NO. 595-95069**

**PROPOSALS DUE SEPTEMBER 8, 2016 AT 11:00 AM**

The attached Addendum (1 page) provides answers to questions that have been asked regarding this project.

**1577 W. 2<sup>nd</sup> STREET – RESERVOIR SITE SECURITY UPGRADE, “WATER FACILITIES AND SECURITY UPGRADES”, PROJECT NO. 595-95069**

Please incorporate the revision in your proposal document and return the acknowledgment of the Addendum 3. Failure to acknowledge receipt of this Addendum may result in rejection of your bid.

Sincerely,

A handwritten signature in blue ink, appearing to read "Nichole Horton", is written over a horizontal line.

Nichole Horton, PE  
Senior Water Resources Engineer

Attachment

cc: File

### ADDENDUM NO. 3

CITY OF POMONA  
WATER/WASTEWATER OPERATIONS DEPARTMENT

The following shall be considered and integrated as part of the proposal for:

**1577 W. 2<sup>nd</sup> Street – Reservoir Site Security Upgrade,  
“Water Facilities and Security Upgrades” Project No. 595-95069**

The following inquiries were made pertaining to the proposed project. Please note the responses below and incorporate them into your proposals.

1. Is this a prevailing wage job?
  - a. Yes.
2. Is there a plan holder or bidders list?
  - a. No.
3. Will the contractor demolish the existing fence post footings, or can they cut the post at the base?
  - a. The existing concrete fence post footings shall be removed completely. The contractor shall not cut the posts and abandon the concrete footings in place.
4. Will the new wrought iron fence be constructed to close the open gap at the western boundary between the existing wrought iron fence and the City’s existing chain link fence?
  - a. Yes. The existing chain link fence at the western boundary will be removed. The new wrought iron fence will be constructed to the boundary of the existing wrought iron fence, at the western property boundary.
5. With the demolition of the existing chain link fence, will the contractor be expected to haul all of the existing material away?
  - a. Yes.

The Bidder shall acknowledge the Confirmation of Receipt of Addendum No. 3 for the subject project.

\*\*\*\*\*END ADDENDUM NO. 3 \*\*\*\*\*

PLEASE FILL OUT ACKNOWLEDGMENT AND RETURN THE RECEIPT EITHER BY  
FAX TO 909-620-6702 OR EMAIL TO NICHOLE\_HORTON@CI.POMONA.CA.US

---

## CONFIRMATION OF RECEIPT OF ADDENDUM

---

**PROJECT: ADDENDUM NO. 3 FOR 1577 W. 2<sup>nd</sup> STREET – RESERVOIR SITE  
SECURITY UPGRADE, “WATER FACILITIES AND SECURITY  
UPGRADES”, PROJECT NO. 595-95069**

TO: All Bidders

RE: Receipt of Addendum

This is to verify receipt of Addendum No. 3, for the 1577 W. 2<sup>nd</sup> Street – Reservoir Site Security Upgrade, “Water Facilities and Security Upgrades, Project No. 595-95069”. By signing this document, you acknowledge receipt of addenda.

We appreciate your cooperation and consideration of a bid submittal for this project.

Nichole Horton, P.E.  
Senior Water Resources Engineer

*RETURN TO Nichole Horton, Project Manager*

---

### ACKNOWLEDGMENT

I have read the above request from the City of Pomona and by signing, I hereby acknowledge receipt of Addendum No. 3, for the 1577 W. 2<sup>nd</sup> Street – Reservoir Site Security Upgrade, “Water Facilities and Security Upgrades, Project No. 595-95069” project.

Total pages: 1 (excluding the confirmation sheet).

By: \_\_\_\_\_  
Title: \_\_\_\_\_  
Company: \_\_\_\_\_  
Date received \_\_\_\_\_