


THE CITY OF
POMONA

Public Works Department



April 29, 2015

TO: Interested Parties

RE: RESERVOIR - 5C, PROJECT NO. 575-93153 RFQ Response to Questions

Revised Due Date: 11:00 am on May 6, 2015 (Wednesday)

1. Page 3, Section 6.B.II Engineer of Record- The RFSOQ requires that the Engineer of Record (EOR) be a licensed structural engineer. What would be the EOR's professional responsibility on this project? Is he/she to assume responsibility for the structural integrity of the reservoir as originally designed or is he/she responsible only for those aspects of the design related to the leakage repair of the reservoir?
 - a. The EOR shall be responsible only for those aspects of the design related to the integrity of the new liner.
2. Is the reservoir currently in operation and if so, what is the operating level range that it is being operated at?
 - a. Yes, 50%
3. Has an AWWA leakage test been performed to determine the rate of leakage of the reservoir?
 - a. No

Sincerely,

A handwritten signature in blue ink, appearing to read "Timotheus Hampton", is written over a horizontal line.

Timotheus Hampton, PE
Senior Water Resources Engineer

cc: File